




राष्ट्रीय राजधानी क्षेत्र और निकटवर्ती क्षेत्र  
वायु गुणवत्ता प्रबंधन आयोग  
Commission for Air Quality Management in  
National Capital Region and  
Adjoining Areas



F. No.11O16/01/ 2022-CAQM.Vol-III

Dated: 22.02.2024

**Subject: Amendments to Direction No. 76 dated 29.09.2023- Regulated use of DG Sets-reg**

Pursuant to a comprehensive review and in supersession of all extant directions / orders / guidelines on the regulations for DG sets, Direction No. 76 dated 29.09.2023 was issued by the Commission under section 12 of the Commission for Air Quality Management in NCR & Adjoining Area, Act, 2021, directing for adoption of the Schedule for regulated operations of DG sets (only as a backup against regular power supply failures) across all sectors in NCR including Industrial, Commercial, Residential and Office establishments etc.

2. As certified Retrofitted Emission Control Devices (RECD) are now also available for 61 to 125 KW capacity range of DG sets, Sr. No 4 & 5 in said Direction No. 76 dated 29.09.2023 are hereby amended as under:

S. No.	DG set Capacity range as mentioned in Direction No. 76	DG Set Capacity range as amended now
4.	125 KW to less than 800 KW	<b>61 KW to less than 800 KW</b>
5.	19 KW to less than 125 KW	<b>19 KW to less than 61 KW</b>

3. All other stipulations under the Direction No 76 dated 29.09.2023 will remain unaltered.

*Arvind Nautiyal*  
( Arvind Nautiyal)

To,

1. The Chief Secretary, Government of NCT of Delhi
2. The Chief Secretary, Government of Haryana
3. The Chief Secretary, Government of Rajasthan
4. The Chief Secretary, Government of Uttar Pradesh

Copy to:

1. Chairman, DPCC
2. Chairman, HSPCB
3. Chairman, RSPCB
4. Chairman, UPPCB
5. Chairman, CPCB.
6. The Chairperson and all Members, CAQM

*Arvind Nautiyal*  
( Arvind Nautiyal)  
Member- Secretary