




राष्ट्रीय राजधानी क्षेत्र और निकटवर्ती क्षेत्र
वायु गुणवत्ता प्रबंधन आयोग
Commission for Air Quality Management in
National Capital Region and
Adjoining Areas



F. No.11016/01/ 2022-CAQM.Vol-III 1165 DT

Dated: 11.12.2024

Subject: Amendment to Direction No. 76 dated 29.09.2023- Regulated use of DG Sets-reg

Direction No. 76 dated 29.09.2023 was issued by the Commission under section 12 of the Commission for Air Quality Management in NCR & Adjoining Area, Act, 2021, directing for adoption of the Schedule for regulated operations of DG sets (only as a backup against regular power supply failures) across all sectors in NCR, including Industrial, Commercial, Residential and Office establishments etc.

2. Owing to availability of certified ECDs now also for DG sets upto 41 kW capacity, as against only up to 61 kW capacity and higher earlier, the schedule for emission control from DG sets Sr. No 4 & 5 in said Direction No. 76 as amended on 22.02.2024, is hereby further partially amended as under:

Sr. No.	DG set Capacity range as amended on 22.02.2024	DG Set Capacity range as amended now
4.	61 KW to less than 800 KW	41 KW to less than 800 KW
5.	19 KW to less than 61 KW	19 KW to less than 41 KW

3. All other stipulations under the Direction No 76 dated 29.09.2023 will remain unaltered

(Arvind Nautiyal)

To,

1. The Chief Secretary, Government of NCT of Delhi
2. The Chief Secretary, Government of Haryana
3. The Chief Secretary, Government of Rajasthan
4. The Chief Secretary, Government of Uttar Pradesh

Copy to:

1. Chairman, DPCC
2. Chairman, HSPCB
3. Chairman, RSPCB
4. Chairman, UPPCB
5. Chairman, CPCB.
6. The Chairperson and all Members, CAQM

(Arvind Nautiyal)
Member- Secretary